


ATTESTATION OF CONFORMITY

Issued to: Guangzhou Realm Energy-Saving Equipment Co., Ltd.
No.1-3, 58 Zhuliao Avenue, Zhongluotan Town, Baiyun District, Guangzhou City,
Guangdong, China

For the product: DC Inverter Heat Pump

Trade name: 

Type/Model: RMAW-04ZR3-V

Ratings: 380-415 V 3N~, 50 Hz, 3650 W, 6,5 A, R32, Class I, IPX4,
Auxiliary heating element: 2850-3450 W (220-240 V)

Manufactured by: Guangzhou Realm Energy-Saving Equipment Co., Ltd.
No.1-3, 58 Zhuliao Avenue, Zhongluotan Town, Baiyun District, Guangzhou City,
Guangdong, China

Requirements: EN 60335-1:2012 + A11:2014 + A13:2017 + A14:2019 + A1:2019 + A2:2019 +
A15:2021
EN 60335-2-40:2003 + A11:2004 + A12:2005 + A1:2006 + A2:2009 + A13:2012
EN 62233:2008

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 4396194.50.

This Attestation implies that the examined types are in accordance with the standards designated under the Low Voltage Directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 23 December 2022

Number: 4396194.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.,
Guangzhou Branch



Rosa Zhou
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed